



**PLEASANTVILLE SCHOOL DISTRICT
PLEASANTVILLE, NEW JERSEY
MICROBIAL REMEDIATION
FINAL CLEARANCE REPORT
SUMMER 2019**

Prepared for:

Pleasantville School District
Pleasantville, New Jersey

Prepared by:

Coastal Environmental Compliance, LLC
P.O. Box 167
Hammonton, NJ 08037
P: 609-685-9984 * F: 609-561-6197
coastalenvironmental@hotmail.com

September 25, 2019

**PLEASANTVILLE SCHOOL DISTRICT
PLEASANTVILLE, NEW JERSEY
MICROBIAL REMEDIATION
FINAL CLEARANCE REPORT
SUMMER 2019**

Prepared By:

Marylee K. Morinelli-Space

Marylee K. Morinelli-Space
President/Member

The information contained in this document is confidential and intended for the exclusive use of the Client named on the cover page, and only with respect to the Facility which is the subject of this document. Any other disclosure, use, copying, distribution or taking of any action in reliance on the contents of this document is prohibited. Coastal Environmental Compliance, LLC. shall not be liable to any person for use of this document, and any information contained therein, except as expressly authorized by Coastal Environmental Compliance, LLC. Coastal Environmental Compliance, LLC. shall not be liable to the Client or any person or entity, in the event the Client fails to respond to the findings or implement the recommendations provided within this document.

The information herein is provided based on current technology and guidelines established by professional and governmental organizations involved in environmental issues. It is based on physical and regulatory conditions in existence at the time the Facility was visited for the purpose of preparing this document, or at the time of document delivery to the Client, if no Facility was visited for the purpose of preparing this document.

©2019 Coastal Environmental Compliance, LLC. All Rights Reserved.

**PLEASANTVILLE SCHOOL DISTRICT
PLEASANTVILLE, NEW JERSEY
MICROBIAL REMEDIATION
FINAL CLEARANCE REPORT
SUMMER 2019**

Table of Contents

1.0 BACKGROUND	4
2.0 APPROACH	4
3.0 FINDINGS & OBSERVATIONS	5
4.0 RECOMMENDATIONS	7
APPENDIX A – Lab Results	

1.0 BACKGROUND

Coastal Environmental Compliance, LLC (Coastal Environmental) was contacted to conduct clearance inspections and testing at the Pleasantville High School, Pleasantville Middle School, Washington Avenue School, South Main Street School and Leeds Avenue School, Pleasantville, New Jersey. This inspection was conducted following a mold remediation at each of the schools listed above.

This report details the complete inspection and testing results for the schools.

2.0 APPROACH

2.1 *SAMPLING METHODOLOGY*

Microbiological air sampling was conducted throughout the affected areas within each property, and one outdoor location using a low flow pump and air-o-cell cassettes (spore traps). Samples were evaluated for total count and identification of fungi, and other particulates.

Swab samples were also collected and identified for fungi.

ProLab, Inc., Weston, Florida performed the analysis, according to guidelines proposed by the USEPA, and the AIHA Field Guide For The Determination Of Biological Contaminants In Environmental Samples, 1996.

3.0 FINDINGS & OBSERVATIONS

3.1 VISUAL INSPECTION

A visual inspection of the buildings was conducted between August & September 2019. The concerns and visual observations are as follows:

- ✚ All areas are free of visible mold.

3.2 SAMPLE RESULTS

3.2.1 Microbiological Testing

Microbiological clearance testing was conducted throughout the buildings between August and September 2018. The results are as follows: Please see attached laboratory results.

SCHOOL	ROOM LOCATIONS	RESULTS
High School	A101, A102, A103, A104, A105, A106, A107, A108, A109, A110, A201, A206, B101, B102, B103, B105, B107, B109, B212, C101, C102, C103, C104, C105, C109, C209, D102, Main Office, Library, JROTC Conference & Main Room, Auditorium, Nurse, Student Services, Music Room.	Passed Clearance
Middle School	Principal's Office, Main Office, Cafeteria, Library, CST1, CST2, Instrument Room, Rms., A103, A105, A122, B201, B209, B210, B310, C101, C102, C105A, C106, C107, C108, C303, C312	Passed Clearance
Washington Avenue School	Rms. 106A, 107, 123, 209 B/A, McGranahan office	Passed Clearance
South Main Street School	Cafeteria, Rms. 101, 103, 110-111, 109, 125, 129, 130 Media Rm., 203	Passed Clearance
Leeds Avenue School	Rms. 106, 118, 126, Library & Library Office, Student Svcs., Cafeteria, Nurse, Main Office, Basement storage door	Passed Clearance

Air & Surface samples indicate the following:

- ✚ All remediated areas were re-inspected and air and surface tested following remediation. Concentration and species were comparable to ambient air. Swab samples indicated normally settled spores.
- ✚ All areas passed visual inspection and air and surface testing.

4.0 RECOMMENDATIONS

Based upon the testing results and visual observations, Coastal Environmental Compliance, LLC recommends the following:

- ✚ No further action required.
- ✚ All remediated areas have passed clearance.
- ✚ All listed affected areas are safe for occupancy.

Coastal Environmental Compliance, LLC is pleased to have provided the Pleasantville School District with professional services.

APPENDIX A

Laboratory Results