

Six Month Inspection Report Pleasantville School District Board of Education

Building Name/Number

South Main Street School	
--------------------------	--

Building Location

701 South Main Street, Pleasantville, NJ	
--	--

Homogeneous ID#	Material	Location	Material Cond.			Total Amt.	Damaged Amt.	Friable	Re
			TYP	DC	PDC				
01	Transite Over Windows	Throughout Building 1970	M	ND	NPD	720 SF	0 SF	N	O&M
02	Slate Windowsills	Throughout Building 1970	M	ND	NPD	750 SF	0 SF	N	O&M
03	Boiler Burners (Assumed)	Boiler Room	T	ND	NPD	10 SF	0 SF	N	O&M
05	Hot Water Heater Insulation (Assumed)	Boiler Room	T	ND	NPD	100 SF	0 SF	Y	New Lag Pernaco,
06	Fire Doors (Assumed)	Boiler Room and Stage Area	M	ND	NPD	60 SF	0 SF	Y	O&M

*Refers to Material Type and Damage Categories

T-Material Type As:	DC-Damage Condition	PD-Potential Damage Categories	**Response Action
S - Surfacing	N - No Damage	NPD - No Potential Damage	Repair
M - Miscellaneous	D - Damage	PD - Potential Damage	Remove
T - Thermal System	SD - Significant	PSD - Potential Significant Damage	Operation & Maintenance Encapsulate

Cathy Ladden

Signature of Person Completing Report

Asbestos Inspector - ACC # 11

Title of Person Completing

**Six Month Inspection Report
Pleasantville School District Board of Education**

Building Name/Number

South Main Street School	
--------------------------	--

Building Location

701 South Main Street, Pleasantville, NJ	
--	--

Homogeneous ID#	Material	Location	Material Cond.			Total Amt.	Damaged Amt.	Friable	Re
			TYP	DC	PDC				
07	12x12 Various Color Floor Tile (Assumed)	Throughout Building 1970 and 1991	M	ND	PD	27,408 SF	0 SF	N	-2400SF in the Li - Floor t bookcas - Floor t in the gy -350SF in the Li ronment

Note: During the week of July 1, 2014, 589 SF of floor tile and mastic was removed from under the HVAC units throughout the school. This was due to the replacement of the HVAC units. For additional info, please see paperwork stored in the main office.

Note: 9x9 Asbestos floor tile may exist under the 12x12 floor tile throughout the school.

*Refers to Material Type and Damage Categories

T-Material Type As:	DC-Damage Condition	PD-Potential Damage Categories	**Response Action
S - Surfacing	N - No Damage	NPD - No Potential Damage	Repair
M - Miscellaneous	D - Damage	PD - Potential Damage	Remove
T - Thermal System	SD - Significant	PSD - Potential Significant Damage	Operation & Maintenance Encapsulate

Cathy Ledden
Signature of Person Completing Report

Asbestos Inspector - ACC # 11
Title of Person Completing